

**American Society of Sanitary Engineering
Seal (Certification) Program**

**Factory Audit Inspection Test for:
Hose Connection Vacuum Breakers**

**Tested under ASSE Standard 1011 • Revised: 2004
Factory Audit Inspection Test**

Manufacturer _____

Model No. _____

Address _____

Serial No. _____

Other Identification Markings _____

Size _____

Connections- Inlet with non-removable feature? **Yes** **No**

3.1 Hydrostatic Pressure Test

What was the supply pressure used for this test? _____ psi (_____ kPa)

The test period was for _____ minutes.

Were there any external leaks or damage to the device?

Yes No Questionable

If questionable, explain: _____

3.6 Low Head Back Pressure Test

With a 6 inch (152.4mm) water column back pressure, is this section in compliance? Yes No Questionable

If questionable, explain: _____

With a 10 foot (3.0m) water column back pressure, is this section in compliance?

Yes No Questionable

If questionable, explain: _____

3.7 Atmospheric Vent Opening Test

In compliance?

Yes No Questionable

If questionable, explain: _____

3.9 Back Siphonage Test

Gradually applied vacuum - In compliance?

Yes No Questionable

If questionable, explain: _____

Rapidly applied vacuum - In compliance? Yes No Questionable
If questionable, explain: _____

Check fouled per Figure _____ Other _____
Explain: _____

The maximum rise of the meniscus in the sight glass was _____ inches
(_____ mm)

TESTING AGENCY _____

ADDRESS _____

PHONE: _____ FAX: _____

TEST ENGINEER(S) _____

We certify that the evaluations are based on our best judgments and that the test data recorded is an accurate record of the performance of the device on test.

Signature of the official of the agency: _____

Title of the official: _____ Date: _____

Signature and seal of the Registered Professional Engineer supervising the laboratory evaluation:

Signature

