

**American Society of Sanitary Engineering
Seal (Certification) Program**

**Factory Audit Inspection Test for:
Backflow Prevention Devices for Hand-Held Showers**

Tested under ASSE Standard 1014 • Revised: January, 2005

Manufacturer _____

Model No. _____

Address _____

Serial No. _____

Other Identification Markings _____

Size _____

Connections – Inlet with non-removable feature Yes No

Section III

3.0 Performance Requirements and Compliance Testing

3.1 Deterioration at Extremes of Temperature and Pressure Test

3.1.2 What was the test pressure? _____ psi (_____ kPa)

What water temperatures were used during the different segments of this test? During 30 minute flow: _____ °F (_____ °C)

During 1 minute flow: _____ °F (_____ °C)

With outlet closed: _____ °F (_____ °C)

In compliance? Yes No

3.3 Backpressure Test

3.3.2 Was there any indication of leakage from the inlet of the device when the discharge end of the hose was raised from 6 inches (152.4 mm) to 60 inches (1524.0 mm)? Yes No

In compliance? Yes No

TESTING AGENCY _____

ADDRESS _____

PHONE: _____ FAX: _____

TEST ENGINEER(S) _____


We certify that the evaluations are based on our best judgments and that the test data recorded is an accurate record of the performance of the device on test.

Signature of the official of the agency: _____

Title of the official: _____ Date: _____

Signature and seal of the Registered Professional Engineer supervising the laboratory evaluation:

Signature



Seal