

*American Society of Sanitary Engineering*  
PRODUCT (SEAL) LISTING PROGRAM  
Factory Audit Inspection Test Report



ASSE STANDARD #1016 - REVISED: 2017  
Automatic Compensating Valves for Individual  
Showers and Tub / Shower Combinations

---

---

MANUFACTURER: \_\_\_\_\_

CONTACT PERSON: \_\_\_\_\_ E-MAIL: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

LABORATORY FILE NUMBER: \_\_\_\_\_

MODEL # TESTED: \_\_\_\_\_

MODEL SIZE: \_\_\_\_\_

ADDITIONAL MODELS REPORT APPLIES TO: \_\_\_\_\_

ADDITIONAL MODEL INFORMATION (i.e. orientation, series, end connections, shut-off valves): \_\_\_\_\_

DATE MODELS RECEIVED BY LABORATORY: \_\_\_\_\_ DATE TESTING BEGAN: \_\_\_\_\_

DATE TESTING WAS COMPLETED: \_\_\_\_\_

IF MODELS WERE DAMAGED DURING SHIPMENT, DESCRIBE DAMAGES: \_\_\_\_\_

PROTOTYPE OR PRODUCTION: \_\_\_\_\_

WERE ALL TESTS PERFORMED AT THE SELECTED LABORATORY?  Yes  No

If offsite, identify location and tests involved: \_\_\_\_\_

**General information and instructions for the testing engineer:**

*The results within this report apply only to the models listed above.*

There may be items for which the judgment of the test engineer will be involved. Should there be a question of compliance with that provision of the standard, a conference with the manufacturer should be arranged to enable a satisfactory solution of the question.

Should disagreement persist and compliance remain in question by the test agency, the agency shall, if the product is in compliance with all other requirements of the standard, file a complete report on the questionable items together with the test report, for evaluation by the ASSE Seal Board. The Seal Board will then review and rule on the question of compliance with the intent of the standard then involved.

Documentation of material compliance must be furnished by the manufacturer. The manufacturer shall furnish to the testing agency, a bill of material which clearly identifies the material of each part included in the product construction. This identification must include any standards which relate thereto.



**SECTION III**

**3.3**

**Minimum Rated Flow**

What is the minimum flow rate as stated by the manufacturer?

\_\_\_\_\_ GPM ( \_\_\_\_\_ L/min)

**SECTION IV**

**4.7**

**Water Supply Failure Test – All Types**

Was the device set up as shown in Figure 1 and in accordance with item (a) to (f) of Section 4.6.3?  Yes  No

The cold water supply valve was closed within \_\_\_\_\_ sec

Was the outlet temperature at T3 and the flow rate recorded for 5 seconds after the cold water supply valve had been fully closed?  Yes  No

The flow rate was reduced to \_\_\_\_\_ GPM ( \_\_\_\_\_ L/min) within 5 seconds

The hot water supply valve was closed within \_\_\_\_\_ sec

Was the outlet temperature at T3 and the flow rate recorded for 5 seconds after the hot water supply valve had been fully closed?  Yes  No

The flow rate was reduced to \_\_\_\_\_ GPM ( \_\_\_\_\_ L/min) within 5 seconds

30% of the manufacturer’s minimum rate flow is \_\_\_\_\_ GPM ( \_\_\_\_\_ L/min)

Did the device reduce the flow to 0.5 GPM (1.9 L/min) or 30% of the manufacturer’s minimum rated flow, whichever is less, within 5 seconds?  Yes  No

Upon cold water failure, did the device reduce the flow to 0.5 GPM (1.9 L/min) or 30% of the manufacturer’s minimum rated flow, whichever is less, prior to the water temperature at T3 exceeding 120.0 °F (48.9 °C)?  Yes  No



**4.8 Mechanical Temperature Limit Stop Test**

Hot water inlet pressure \_\_\_\_\_ psi ( \_\_\_\_\_ kPa)  
 Cold water inlet pressure \_\_\_\_\_ psi ( \_\_\_\_\_ kPa)  
 Flow rate through the device \_\_\_\_\_ GPM ( \_\_\_\_\_ L/min)  
 Hot water inlet temperature \_\_\_\_\_ °F ( \_\_\_\_\_ °C)  
 Cold water inlet temperature \_\_\_\_\_ °F ( \_\_\_\_\_ °C)  
 Limit stop was set to an outlet temperature of \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

With the device set at the full hot position and flowing for 1 minute, what was the outlet temperature at T3? \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

A torque of \_\_\_\_\_ LB•in ( \_\_\_\_\_ N•M) was applied to the temperature control handle/valve stem for \_\_\_\_\_ sec

While applying the torque for 1 minute, what was the outlet temperature at T3? \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

Did the outlet temperature while applying the torque exceed the outlet temperature before applying the torque by 3.6 °F (2.0 °C) or greater?  Yes  No

Were there any observable fractures in the limit stop?  Yes  No

**4.9 Outlet Temperature and Flow Capacity Test**

Hot water inlet pressure \_\_\_\_\_ psi ( \_\_\_\_\_ L/min)  
 Cold water inlet pressure \_\_\_\_\_ psi ( \_\_\_\_\_ L/min)

During this test, were the inlet temperatures maintained within ±2.0 °F (±1.0 °C) without exceeding specified limits?  Yes  No

Valve V3 was adjusted to deliver \_\_\_\_\_ GPM ( \_\_\_\_\_ L/min)

Cold inlet temperature was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)  
 Hot inlet temperature was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

After setting the device to the full cold position, the device was adjusted to an outlet temperature of \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

After flowing for 1 minute, the outlet temperature was \_\_\_\_\_ °F ( \_\_\_\_\_ °C) and the flow rate was \_\_\_\_\_ GPM ( \_\_\_\_\_ L/m)

Cold inlet temperature was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)  
 Hot inlet temperature was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)



After setting the device to the full cold position, the device was adjusted to an outlet temperature of \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

After flowing for 1 minute, the outlet temperature was \_\_\_\_\_ °F ( \_\_\_\_\_ °C) and the flow rate was \_\_\_\_\_ GPM ( \_\_\_\_\_ L/m)

The temperature limit stop was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

When the device was set to the full hot position and water flowed for 1 minute, the outlet temperature was \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

Cold inlet temperature was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)  
Hot inlet temperature was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

After setting the device to the full cold position, the device was adjusted to an outlet temperature of \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

After flowing for 1 minute, the outlet temperature was \_\_\_\_\_ °F ( \_\_\_\_\_ °C) and the flow rate was \_\_\_\_\_ GPM ( \_\_\_\_\_ L/min)

The temperature limit stop was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

When the device was set to the full hot position and water was flowed for 1 minute, the outlet temperature was \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

Cold inlet temperature was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)  
Hot inlet temperature was set to \_\_\_\_\_ °F ( \_\_\_\_\_ °C)  
A minimum out temperature was maintained at \_\_\_\_\_ °F ( \_\_\_\_\_ °C)

After flowing for 1 minute, the outlet temperature was \_\_\_\_\_ °F ( \_\_\_\_\_ °C) and the flow rate was \_\_\_\_\_ GPM ( \_\_\_\_\_ L/m)

Did the device fail to flow a minimum of 2.25 GPM (8.5 L/min) or the manufacturer's minimum rated flow?  Yes  No

Was the device able to be adjusted to a minimum outlet water temperature of 100.0 °F (37.8 °C)?  Yes  No

Was the device able to limit the outlet temperature to a maximum of 120.0 °F (48.9 °C)?  Yes  No



**SECTION V**  
5.0

**Marking Packaging and Installation Instructions and Included Literature**

Identify markings contained on the device: \_\_\_\_\_  
\_\_\_\_\_

Were markings clear, permanent and visible after installation?  Yes  No

Does the device have identifiable control settings?  Yes  No

Describe the settings: \_\_\_\_\_  
\_\_\_\_\_

Were manufacturer's instructions for installation, adjustment and maintenance included in the packaging?  Yes  No

If the device is not equipped with an integral shut-off, was a warning included in the instructions to install check valves on the inlets?  Yes  No

Were instructions provided on how the handle position or the limit setting is to be adjusted?  Yes  No

Did the packing or literature specify the device's minimum flow rate, determined at a flowing pressure of 45.0 psi (310.3 kPa)?  Yes  No

LISTED LABORATORY: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

TEST ENGINEER(S): \_\_\_\_\_

If applicable:

OUTSOURCED LABORATORY: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

PHONE: \_\_\_\_\_ FAX: \_\_\_\_\_

TEST ENGINEER(S): \_\_\_\_\_

Scope of outsourced testing: \_\_\_\_\_

We certify that the evaluations are based on our best judgments and that the test data recorded is an accurate record of the performance of the device on test.

Signature of the official of the listed laboratory: \_\_\_\_\_  
Signature

Title of the official: \_\_\_\_\_ Date: \_\_\_\_\_